Verification No.: CLJS25082975208

VERIFICATION OF LVD COMPLIANCE

Applicant:	ProJoy Electric Co., Ltd.
Address of applicant:	No.90 Chunyao Rd Xiangcheng District, Suzhou, Jiangsu, China
Manufacturer:	ProJoy Electric Co., Ltd.
	No.90 Chunyao Rd Xiangcheng District, Suzhou, Jiangsu, China
Product Description:	Automatic Transfer Switch
Model No.:	PEATS-63R/2P, PEATS-63R/4P
Rating:	See the annex

Sufficient samples of the product have been reviewed and found to be in conformity with

Review Standard:	EN IEC 60947-6-1:2023
As shown in the	TLJS25082975208
TCF Number(s):	
Date of issue:	September 05th, 2025
Date of expiry:	September 04th, 2030

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd.. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd

GLOBAL TESTING SERVICES CO., LTD. GTS CERTIFICATION

Global Testing Services Co., Ltd
E-mail:info@gts-lab.com http://www.gts-lab.com
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

ZERTIFIKAT ■ CERTIFICATE ■ CERTIFNÓNKAT ■ CERTIFICADO ■ CERTIFICAT

Annex:

Rated operating current Ie(A): 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A

Rated insulation voltage Ui: 690V

Rated impulse withstand voltage Uimp: 8kV

Rated working voltage Ue: AC110V/230V

Rated frequency: 50/60Hz

Class: PC

Pole number: 2P/4P

Rated short-circuit current Iq :50kA

Short circuit protection device (fuse): RT16-00-63A

Control circuit: Rated control voltage Us: AC230V/110v, 50/60Hz

Normal working conditions: 85%Us-110%Us

Auxiliary circuit: AC110V/230V 50/60Hz Ie=5A

Mechanical life: ≥8000 times

Electrical life: 31500 times

Usage category: AC-31B

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd

Global Testing Services Co., Ltd
E-mail:info@gts-lab.com http://www.gts-lab.com
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

ZERTIFIKAT ■ CERTIFICATE ■ СЕРТИФИКАТ ■ CERTIFICADO ■ CERTIFICAT